



Momentum Technologies, inc.

Date: July 27, 2010
MTi Project No.: CX07E0D-1
Phone No.: 512-637-1200
Fax No.:
Customer P.O.#: 60466

Technical Service Report

Accreditations



Cert No. 2711.01

ISO 17025



Associations



Prepared for:

Paul Brown

Customer:

Bautex Systems, LLC
5602 Central Texas Dr.
San Marcos, TX 78666

Testing Laboratory:

Momentum Technologies, inc.
1507 Boettler Rd.
Uniontown, OH 44685

Date:

July 27, 2010

Samples:

1 quart labeled AMB 20-WP produced on May 3, 2010
made for Momentum Technologies, inc.

MTi Sample ID:

MTi-100360 received by
Momentum Technologies, inc. on May 5, 2010.

Project Number:

CX07E0D-1



Momentum Technologies, inc.

Date: July 27, 2010
MTi Project No.: CX07E0D-1
Phone No.: 512-637-1200
Fax No.:
Customer P.O.#: 60466

Accreditations



1.0 Abstract



1.1 Analysis of one liquid applied membrane in accordance with ASTM D 1970

Section 8.9.1, Self Sealability for ABAA Approval .



2.0 Procedure

Cert No. 2711.01

2.1 The tests specimens consisted of 2- 12" x 12" APA Grade 3/8" plywood coated with the material being tested. Two roofing nails were driven through the material and the plywood with the head of the nail raised approximately .25" per sections 8.9.3.1 and 8.9.3.2. Then a 1 gallon can was placed over the nails and then sealed with a .25" bead of silicone per section 8.9.3.3. Once the silicone was cured 5" of water was added to each of the gallon cans placed over the material, the specimens were then placed inside a freezer set at 40° F for a period of 3 days per section 8.9.3.4. The specimens were checked on a daily bases for any signs of leakage.

ISO 17025



Associations



3.0 Results

3.1 The specimens exhibited no signs of water passing through the material after 3 days at 40° F.



4.0 Conclusion

4.1 **PASS**





Momentum Technologies, inc.

Date: July 27, 2010
MTi Project No.: CX07E0D-1
Phone No.: 512-637-1200
Fax No.:
Customer P.O.#: 60466

Accreditations



Cert No. 2711.01

ISO 17025



Associations



If you should have any questions or require any additional information, please call us at 330/896-5900.

Tested by,

Rodney G. Armstrong
Project Engineering Manager

Verified by,

Cindy L. Campbell
Project Manager

The information presented in this publication is based upon the research of Momentum technologies, inc. (MTi) and is to the best of its knowledge accurate. However, no guarantee of its accuracy can be made since MTi has no control over the conditions under which its products may be used by others. MTi assumes no liability for its use, or the failure of products described herein. MTi MAKES NO WARRANTIES EXPRESSED OR IMPLIED, OF MERCHANTABILITY, FITNESS, PATENT INFRINGEMENT, OR OTHERWISE. MTi SHALL NOT BE LIABLE FOR SPECIAL, INCIDENTAL AND/OR CONSEQUENTIAL DAMAGES. No statement contained herein shall be construed as a recommendation or inducement to infringe existing patents or as an endorsement of products of specific manufacturers. ALL TEST REPORTS SHALL NOT BE REPRODUCED, EXCEPT IN FULL WITHOUT THE WRITTEN APPROVAL OF MOMENTUM TECHNOLOGIES, INC.